

Optimal decoupling controllers revisited\*

by

Vladimír Kučera<sup>†‡</sup>

Czech Technical University in Prague,  
Faculty of Electrical Engineering,  
Technická 2, 16627 Prague 6  
and Institute of Information Theory and Automation,  
Academy of Sciences of the Czech Republic  
kucera@fel.cvut.cz

**Abstract:** The problem of decoupling a linear system by dynamic compensation into multi-input multi-output subsystems is studied by applying proper and stable fractional representations of transfer matrices. A necessary and sufficient condition is given for a decoupling and a stabilizing controller to exist. The set of all controllers that decouple and simultaneously stabilize the system is determined in parametric form. Optimal decoupling controllers are then obtained by an appropriate selection of the parameter.

**Keywords:** linear systems, fractional representations, decoupling controllers, stabilizing controllers, optimal controllers.

## 1. Introduction

Decoupling is a way to decompose a complex system into non-interacting subsystems. In fact, certain applications necessitate controlling independently different parts of the system. Even if this is not required, the absence of interaction can significantly simplify the synthesis of the desired control laws.

The decoupling problem has received much attention in the literature. For linear systems, different approaches have been used and control laws of various structure and complexity applied.

The basic form of decoupling into single-input single-output subsystems is often referred to as the diagonal decoupling. This problem was posed by Voznesenskij (1936) and studied by Kavanagh (1957), Strejc (1960), Mejerov (1965),

---

\*Submitted: May 2012; Accepted: October 2012

<sup>†</sup>The original version of this paper was presented at the 18th International Conference on Process Control that was held in Tatranska Lomnica, Slovakia during June 2011.

<sup>‡</sup>Supported by the Technology Agency of the Czech Republic, Competence Centres Programme, project TE01020197 Centre for Applied Cybernetics 3

and Wolovich (1974). The studies were related to the inversion problem of rational matrices. Attention was paid to the existence of proper rational transfer matrices. The issue of stability, however, was not properly addressed.

A deeper insight was provided by the state-space approach. The pioneering work is due to Morgan (1964), who posed the problem of decoupling by static state feedback. Falb and Wolovich (1967) established a solvability condition while Gilbert (1969) related this condition to state feedback invariants of the system. Descusse and Dion (1982) then interpreted this condition in terms of system's structure at infinity.

The use of restricted static state feedback, namely the static output feedback, in decoupling was studied by Howze and Pearson (1970), Howze (1973), Denham (1973), Hazlerigg and Sinha (1978), Filev (1982b), Descusse and Malabre (1982), and Descusse, Lafay and Kučera (1984). This is a very restricted problem, whose solution is hard to obtain, but it is very useful in applications.

A more general form of decoupling into multi-input multi-output subsystems is referred to as the block decoupling. This problem was introduced by Wonham and Morse (1970) and Basile and Marro (1970). Using a geometric approach, they determined the solvability of the problem by static state feedback in several special cases. An alternative algebraic approach based on the structure algorithm was presented by Silverman and Payne (1971). Relationships between the two approaches were studied by Filev (1982a).

The decoupling by dynamic state feedback was studied via the geometric approach by Morse and Wonham (1970), who obtained a deep insight into the internal structure of the decoupled system. By this time, the problem of decoupling by dynamic state feedback was solved, including stability or pole distributions that may be achieved while preserving a decoupled structure. The status of non-interacting control was reviewed by Morse and Wonham (1971).

A comeback of the transfer function methods in the study of block decoupling is witnessed through the works of Koussiouris (1979), Hautus and Heymann (1983), and Kučera (1983). A dynamic state feedback was shown to be equivalent to combined dynamic output feedback and feedforward reference compensation, often referred to as a two-degree-of-freedom controller. To address stability issues, the Youla-Kučera parameterization of all stabilizing controllers was invoked. The basic results are reported by Kučera (1983), Hautus and Heymann (1983), and Gómez and Goodwin (2000). The class of all decoupled transfer matrices that can be achieved by a stabilizing controller was parameterized by Desoer and Gündes (1986) and Lee and Bongiorno (1993). This result has made it possible to derive the  $H_2$ -optimal decoupling controller, which minimizes the performance deterioration due to decoupling.

The two-degree-of-freedom controller structure is ideally suited to decoupling since only one of the degrees of freedom is affected by the decoupling requirement. This is not true for a pure feedback, or a one-degree-of-freedom controller. This case is considerably more difficult to solve, as shown by Hammer and Khargonekar (1984), Lin (1997), Youla and Bongiorno (2000), Bongiorno and Youla (2001), and Park (2008a).

Finally, the decoupling in the generalized plant model, which covers a broad range of control problems in a unified setting, was considered by Park (2008b). Such a plant model can accommodate non-square plant and non-unity feedback cases with one-degree-of-freedom or two-degree-of-freedom controller configuration. The benefits of such a general problem formulation consist in a unified treatment rather than in simplicity of the solution. Indeed, matrix operations need to be converted to vector operations with vectors of a much larger dimension, which result from the Kronecker and Khatri-Rao products of matrices.

This paper adopts the most general setting that is meaningful for decoupling: a system in which the measurement output may be different from the output to be decoupled and a dynamic controller that features both feedback and feed-forward parts. The class of all such controllers that decouple and stabilize the system is determined in parametric form and the parameter is used to obtain the  $H_2$ -optimal controller. The solution is simple and direct. The controller configuration implies that decoupling and stability are two independent issues.




Figure 1. Control system

## 2. Problem formulation

Consider a linear, time-invariant, differential system governed by the input-output relation

$$y = S_y u, \quad (1)$$

where  $u$  is the  $q$ -vector input,  $y$  is the  $p$ -vector output and  $S_y$  is the transfer matrix of the system. We assume that  $S_y$  is a proper rational matrix over  $\mathbb{R}(s)$ , the field of rational functions.

Let  $p_1, \dots, p_k$  be a given set of positive integers that satisfy

$$\sum_{i=1}^k p_i = p.$$

System (1) is said to be *decoupled*, or more specifically  $(p_1, \dots, p_k)$ -decoupled, if there exist positive integers  $q_1, \dots, q_k$  satisfying

$$\sum_{i=1}^k q_i = q$$

such that  $S_y$  has the block diagonal form

$$S_y := \begin{bmatrix} S_1 & & \\ & \ddots & \\ & & S_k \end{bmatrix},$$

where  $S_i$  is  $p_i \times q_i$ .

This is not a generic property of the system, but it can be achieved by a suitable compensation. To this effect, let  $z$  denote the  $m$ -vector output of the system that is available for measurement and let it be related with the input by the equation

$$z = S_z u, \quad (2)$$

where  $S_z$  is a proper rational matrix over  $\mathbb{R}(s)$ .

The most suitable linear, time-invariant, differential controller can then be described by the equation

$$u = K_v v + K_z z, \quad (3)$$

where  $v$  is an external reference input of appropriate dimension, say  $r$ . As it is seen in Fig. 1, the transfer matrices  $K_v$  and  $K_z$  represent the feedforward and the feedback parts of the controller, respectively. We assume that both  $K_v$  and  $K_z$  are proper rational matrices over  $\mathbb{R}(s)$ .

The *decoupling problem* is then to find matrices  $K_v$  and  $K_z$  such that the transfer matrix

$$T = S_y(I - K_z S_z)^{-1} K_v \quad (4)$$

from  $v$  to  $y$  be suitably block diagonal.




Figure 2. Control system with the complete set of independent inputs and outputs

Obviously, unless additional provisions are made, the decoupling problem is trivial as it could be solved by  $K_v = 0$ . Thus, it is necessary to impose certain admissibility condition on the decoupling controller to make the problem meaningful, for example

$$\text{rank } T = \text{rank } S_y \quad (5)$$

over  $\mathbb{R}(s)$ . This condition is equivalent to the preservation of the class of controlled output trajectories. We thus require that no essential loss of control occurs through the decoupling process.

Another requirement, frequently imposed on the decoupled system in practice, is that of stability. This requirement means that the states of the system go to zero from any initial value.

### 3. Preliminaries

A stable system gives rise to a proper and stable transfer function. In order to study stability of the decoupled system it is convenient to express the transfer matrices of the given system and those of the controller in the following factorized form

$$\begin{aligned} \begin{bmatrix} S_z \\ S_y \end{bmatrix} &:= \begin{bmatrix} B \\ C \end{bmatrix} A^{-1} \\ \begin{bmatrix} K_z & K_v \end{bmatrix} &:= P^{-1} \begin{bmatrix} -Q & R \end{bmatrix}, \end{aligned}$$

where

$$A, \begin{bmatrix} B \\ C \end{bmatrix}$$

are proper and stable rational matrices that are right coprime and

$$P, \begin{bmatrix} -Q & R \end{bmatrix}$$

are proper and stable rational matrices that are left coprime.

These proper and stable fractional representations exist and are unique up to right and left multiplication, respectively, by a unimodular matrix. Recall that a proper and stable rational matrix is said to be unimodular if its inverse exists and is proper and stable.

The system equations (1) and (2) and the controller equation (3) then take the form

$$\begin{bmatrix} z \\ y \end{bmatrix} = \begin{bmatrix} B \\ C \end{bmatrix} A^{-1} u, \quad (6)$$

$$u = P^{-1} \begin{bmatrix} -Q & R \end{bmatrix} \begin{bmatrix} z \\ v \end{bmatrix}. \quad (7)$$

The overall system transfer function reads

$$T = C(PA + QB)^{-1}R. \quad (8)$$

The fundamental assumption we make here is that the part of the given system that is not controllable from  $u$  is stable and the part of the given system that is not jointly observable from  $y, z$  is stable. Similarly, we assume that the controller is realized in such a manner that its part that is not jointly controllable from  $v, z$  is stable and its part that is not observable from  $u$  is stable.

The issue of stability of the overall system is then solved as follows.

*Lemma 1.* *The overall system described by (6) and (7) is stable if and only if the matrix  $PA + QB$  is unimodular.*

*Proof.* In the overall system, inject inputs  $x$  and  $w$  as shown in Fig. 2. Then the overall system is stable if and only if the nine transfer matrices between the inputs  $v, w, x$  and the outputs  $u, y, z$ , given by

$$\begin{bmatrix} u \\ z \\ y \end{bmatrix} = \begin{bmatrix} A \\ B \\ C \end{bmatrix} (PA + QB)^{-1} \begin{bmatrix} P & -Q & R \end{bmatrix} \begin{bmatrix} x \\ w \\ v \end{bmatrix}$$

are all well defined and proper and stable rational. This statement follows from the assumption of stability of the uncontrollable and unobservable parts of the system.

Now, in view of the coprimeness assumptions on  $A, B, C$  and  $P, Q, R$  these transfer matrices are well defined and stable if and only if  $PA + QB$  is a unimodular matrix.  $\square$

#### 4. Problem solvability

A necessary and sufficient condition will now be established for a system to be decoupled and stable.

Based on the partition  $(p_1, \dots, p_k)$ , write

$$C := \begin{bmatrix} C_1 \\ \vdots \\ C_k \end{bmatrix}, \quad (9)$$

where  $C_i$  is a  $p_i \times q$  submatrix.

*Theorem 1.* *Given system (1), (2) in fractional form (6) and partition (9), there exists an admissible controller (3) such that the overall system is*

- (i) *stable if and only if  $A$  and  $B$  are right coprime,*
- (ii) *decoupled if and only if*

$$\sum_{i=1}^k \text{rank } C_i = \text{rank } C. \quad (10)$$

*Proof.* (i) Let the overall system be stable. By Lemma 1, the matrix  $PA + QB$  is unimodular whence  $A$  and  $B$  must be right coprime.

Conversely, let the matrices  $A$  and  $B$  of (6) be right coprime. Then there exist proper and stable rational matrices  $P$  and  $Q$  such that

$$PA + QB = I \quad (11)$$

with  $P$  invertible and the inverse of  $P$  proper.

Then, controller (3) in fractional form (7) that is defined by the matrices  $P$  and  $Q$  from (11) and by an arbitrary proper and stable rational matrix  $R$  satisfying  $\text{rank } CR = \text{rank } C$  is admissible since, by (8),

$$\text{rank } T = \text{rank } CR = \text{rank } C = \text{rank } S_y.$$

The resulting system (1), (2) and (3) is stable in view of Lemma 1 and identity (11).

(ii) Let (7) be an admissible decoupling controller for system (6). Denote

$$K := (PA + QB)^{-1}R.$$

The block diagonal property of the matrix  $T$  then implies

$$\text{rank } CK = \sum_{i=1}^k \text{rank } C_i K$$

and the admissibility of the controller gives

$$\text{rank } C_i K = \text{rank } C_i, \quad i = 1, \dots, k.$$

Therefore (10) holds.

The sufficiency will be proved by constructing a suitable  $R$ . Denote

$$r_i := \text{rank } C_i, \quad i = 1, \dots, k.$$

Then there exists a  $p_i \times p_i$  unimodular proper and stable rational matrix  $U_i$  such that

$$C_i = U_i \begin{bmatrix} C'_i \\ 0 \end{bmatrix}, \quad (12)$$

where the rows of  $C'_i$  are linearly independent over  $\mathbb{R}(s)$  and where the zero matrix has  $p_i - r_i$  rows and may be empty. If (10) holds, then

$$C' := \begin{bmatrix} C'_1 \\ \vdots \\ C'_k \end{bmatrix}$$

has linearly independent rows over  $R(s)$ . Hence, there exists a  $q \times q$  unimodular proper and stable rational matrix  $U'$  such that

$$C'U' := \begin{bmatrix} D_1 & & 0 \\ & \ddots & \vdots \\ & & D_k & 0 \end{bmatrix}, \quad (13)$$

where  $D_i$  is an  $r_i \times r_i$  diagonal proper and stable rational matrix and where the zero matrices have  $q - r$  columns with  $r$  defined by

$$r := \sum_{i=1}^k r_i.$$

Define an admissible controller (7) by the matrices  $P$  and  $Q$  from (11) and by the matrix  $R$  formed by the first  $r$  columns of  $U'$ . The transfer matrix (8)

$$T = CR = \begin{bmatrix} U_1 & & \\ & \ddots & \\ & & U_k \end{bmatrix} \begin{bmatrix} \begin{bmatrix} D_1 \\ 0 \end{bmatrix} & & \\ & \ddots & \\ & & \begin{bmatrix} D_k \\ 0 \end{bmatrix} \end{bmatrix} \quad (14)$$

is block diagonal. The resulting system is therefore decoupled and the external reference input  $v$  has dimension  $r$ .  $\square$

The interpretation of these solvability conditions is as follows. Condition (11) corresponds to the stability of the subsystem of the given system that is not observable at the measured output  $z$ . Condition (11) calls for the linear independence of any two outputs of the given system that belong to different blocks. The solvability of the decoupling problem thus strongly depends on the partition  $(p_1, \dots, p_k)$ , that is to say, upon the allocation of the outputs into the blocks.

## 5. Controller parameterization

When a decoupling and stabilizing controller exists, we shall parameterize the class of all such controllers.

The control system (6), (7) is stable if and only if  $PA + QB$  is a unimodular matrix by Lemma 1. Thus, stabilization involves only the feedback part  $K_z$  of the controller, which surrounds the measurement subsystem  $S_z$ . As a result, the parameterization of  $K_z$  amounts to the well-known Youla-Kučera parameterization of feedback stabilizing controllers. For details, see Kučera (1975), Youla, Jabr and Bongiorno (1976), Kučera (1979), Desoer et al. (1980), and Vidyasagar (1985).

Let  $\bar{P}$ ,  $\bar{Q}$  be any solution pair of equation (11). Then the solution class of (11) is given by

$$P = \bar{P} + W\bar{B}, \quad Q = \bar{Q} - W\bar{A}, \quad (15)$$



where  $\bar{A}$  and  $\bar{B}$  are left coprime, proper and stable rational matrices such that

$$\bar{A}^{-1}\bar{B} = BA^{-1} \quad (16)$$

and  $W$  is an arbitrary proper and stable rational matrix parameter.

The class of all stabilizing proper rational  $K_z$  is then obtained in the form

$$K_z = -P^{-1}Q = -(\bar{P} + W\bar{B})^{-1}(\bar{Q} - W\bar{A}), \quad (17)$$

where the parameter  $W$  is constrained so that the inverse of  $\bar{P} + W\bar{B}$  exists and is proper rational.

Once the control system (6) and (7) is stabilized, it is decoupled if and only if  $T = CR$  by (8). Thus, decoupling involves only the feedforward part  $K_v$  of the controller.

Partition the  $q \times q$  unimodular matrix  $U'$  defined in (13) as

$$U' = \begin{bmatrix} U'_r & U'_{q-r} \end{bmatrix},$$

where  $U'_r$  has  $r$  columns and  $U'_{q-r}$  has  $q - r$  columns and may be empty. The class of all decoupling proper rational  $K_v$  is then given by  $K_v = P^{-1}R$  with  $P$  determined in (14) and

$$R = U'_r \begin{bmatrix} V_1 & & \\ & \ddots & \\ & & V_k \end{bmatrix}, \quad (18)$$

where  $V_i$  is an arbitrary  $r_i \times r_i$  proper and stable rational matrix parameter. The matrices  $V_1, \dots, V_k$ , in turn, parameterize the class of achievable block-diagonal transfer matrices (8) as follows

$$T = \begin{bmatrix} U_1 & & \\ & \ddots & \\ & & U_k \end{bmatrix} \begin{bmatrix} \begin{bmatrix} D_1 \\ 0 \end{bmatrix} & & \\ & \ddots & \\ & & \begin{bmatrix} D_k \\ 0 \end{bmatrix} \end{bmatrix} \begin{bmatrix} V_1 & & \\ & \ddots & \\ & & V_k \end{bmatrix}. \quad (19)$$

The parameterization of decoupling stabilizing controllers reveals that decoupling and stabilization are two independent issues. That is why the controller described by (3) is called the two-degree-of-freedom controller. However, this is no longer true for one-degree-of-freedom controllers, e.g., for the error-actuated controllers described by  $u = -P^{-1}Q(v - w)$  in place of (7).

## 6. Optimal controllers

The decoupling constraint can deteriorate system's performance. The bonus of having a parameterized solution set is that the lost performance can easily be

optimized. Optimal decoupling controllers can be obtained by an appropriate choice of the parameters  $V_1, \dots, V_k$  and  $W$ .

Suppose that the control objective is for each block of outputs  $y_i$  to track the corresponding block of reference inputs  $v_i$ . Thus, we suppose that  $p_i = r_i$  for  $i = 1, \dots, k$ , i.e., there are as many reference inputs as controlled outputs in each block. The tracking error for each block is given by

$$e_i := v_i - y_i = H_i v_i.$$

In view of (19),  $H_i$  has the generic form

$$H_i = I - F_i V_i, \quad (20)$$

where  $F_i := U_i D_i$  and  $V_i$  are proper and stable rational matrices with  $F_i$  fixed and  $V_i$  an arbitrary parameter to be specified.

The benefits of controller parameterization will now be demonstrated in the case of  $H_2$  control design, see Kučera (2011). It turns out that only the parameters  $V_1, \dots, V_k$  are subject to selection, whereas  $W$  is free and can be independently selected to accommodate additional design specifications.

Suppose that for each block, the reference-to-error transfer function  $H_i$  is to have the least  $H_2$  norm defined by

$$\|H_i\|_2 := \left( \text{trace} \frac{1}{2\pi} \int_{-\infty}^{\infty} H_i^*(j\omega) H_i(j\omega) d\omega \right)^{1/2},$$

where the asterisk denotes the conjugate transpose. Thus,  $H_i^*(s) := H_i^T(-s)$  for any complex argument  $s$ .

To achieve this task, determine the inner-outer factorization of  $F_i$ ,

$$F_i = F_{iI} F_{iO},$$

where  $F_{iI}$  is inner and  $F_{iO}$  is outer. Since  $F_i$  is square and nonsingular,  $F_{iI}$  satisfies  $F_{iI}^* F_{iI} = I$  and  $F_{iO}$  is free of zeros in  $\text{Res} > 0$ .

Since  $F_{iI}$  is inner, left multiplication by  $F_{iI}^*$  preserves the  $H_2$  norm,

$$\|H_i\|_2 = \|F_{iI}^* H_i\|_2 = \|F_{iI}^* - F_{iO} V_i\|_2.$$

Observe that  $F_{iI}^*(\infty) = I$ . Separate the strictly proper part,  $F_{iIsp}^*$ , of  $F_{iI}^*$  as follows

$$F_{iI}^* = I + F_{iIsp}^*$$

and note that, by definition,  $F_{iIsp}^*$  has poles only in  $\text{Res} > 0$ . Then

$$\begin{aligned} \|H_i\|_2^2 &= \|F_{iIsp}^* + (I - F_{iO} V_i)\|_2^2 \\ &= \|F_{iIsp}^*\|_2^2 + \|I - F_{iO} V_i\|_2^2 \end{aligned}$$

because the cross terms contribute nothing to the norm. This is a complete square in which only the second term depends on  $V_i$ . Therefore, a unique  $V_i$  that attains the minimum of the norm for subsystem  $i$  is

$$V_i = F_{iO}^{-1}. \quad (21)$$

However, only a proper and stable  $V_i$  is admissible. It follows that the  $H_2$  control problem for subsystem  $i$  has a solution if and only if  $F_{iO}$  is unimodular. The minimum norm is then given by

$$\min_{V_i} \|H_i\|_2 = \|F_{iO}\|_2.$$

Other performance requirements can be addressed by the choice of  $W$ ; for example, Kučera (2012) studies asymptotic tracking of a reference.

## 7. An example

Consider a system defined by (1), (2) with the transfer matrices

$$S_y = \begin{bmatrix} 1 & \frac{s+2}{s-1} \\ \frac{s-1}{s+2} & 2 \end{bmatrix}, \quad S_z = \begin{bmatrix} \frac{2s+1}{s+2} & \frac{3s}{s-1} \\ \frac{s-1}{s+2} & 2 \end{bmatrix}.$$

Thus, the measurement output  $z$  is different from the output  $y$  to be decoupled in that it involves a non-unity feedback sensor.

The task is to determine a two-degree-of-freedom controller (3) that (1, 1)-decouples and stabilizes the system.

The first step is to obtain a proper and stable fractional representation (6) for the system. Standard calculations yield

$$A = \begin{bmatrix} 1 & 0 \\ 0 & \frac{s-1}{s+2} \end{bmatrix},$$

$$B = \begin{bmatrix} \frac{2s+1}{s+2} & \frac{3s}{s+2} \\ \frac{s-1}{s+2} & 2 \frac{s-1}{s+2} \end{bmatrix}, \quad C = \begin{bmatrix} 1 & 1 \\ \frac{s-1}{s+2} & 2 \frac{s-1}{s+2} \end{bmatrix}.$$

Now apply Theorem 1. Since  $A$  is right coprime to  $B$ , a stabilizing controller exists. Since the rank of  $C$  equals the sum of the ranks of the rows of  $C$ , an admissible decoupling controller exists as well.

All stabilizing and decoupling controllers will be parameterized using the fractional representation (7). To obtain the feedback part of the controller, we consider any particular solution of equation (11), for example

$$\bar{P} = \begin{bmatrix} 1 & 0 \\ -\frac{2s+1}{s+2} & -2 \end{bmatrix}, \quad \bar{Q} = \begin{bmatrix} 0 & 0 \\ 1 & 0 \end{bmatrix}.$$

A left coprime fractional representation that satisfies (15) is given by

$$\bar{A} = \begin{bmatrix} 0 & 1 \\ -\frac{s-1}{s+2} & 0 \end{bmatrix}, \quad \bar{B} = \begin{bmatrix} \frac{s-1}{s+2} & 2 \\ -\frac{(s-1)(2s+1)}{(s+2)^2} & -\frac{3s}{s+2} \end{bmatrix}.$$

Thus, the solution class (15) of equation (11) is

$$\begin{aligned} P &= \begin{bmatrix} 1 & 0 \\ -\frac{2s+1}{s+2} & -2 \end{bmatrix} + W \begin{bmatrix} \frac{s-1}{s+2} & 2 \\ -\frac{(s-1)(2s+1)}{(s+2)^2} & -\frac{3s}{s+2} \end{bmatrix} \\ Q &= \begin{bmatrix} 0 & 0 \\ 1 & 0 \end{bmatrix} - W \begin{bmatrix} 0 & 1 \\ -\frac{s-1}{s+2} & 0 \end{bmatrix}. \end{aligned} \quad (22)$$

To obtain the feedforward part of the controller, note that  $U_1 = U_2 = 1$  and the unimodular matrix defined in (13) equals

$$U' = \begin{bmatrix} 2 & -1 \\ -1 & 1 \end{bmatrix}.$$

Thus, (17) yields

$$R = \begin{bmatrix} 2 & -1 \\ -1 & 1 \end{bmatrix} \begin{bmatrix} V_1 & 0 \\ 0 & V_2 \end{bmatrix}. \quad (23)$$

The matrices  $P$ ,  $Q$  in (22) and  $R$  in (23) define the class of all controllers that solve the given problem. The parameters  $V_1$ ,  $V_2$  are free proper and stable rational functions and  $W$  is permitted to range over proper and stable rational  $2 \times 2$  matrices so that the inverse of  $P$  exists and is proper. Obviously, this means that  $P(\infty)$  is to be a nonsingular matrix.

The decoupled transfer matrices that can be achieved in this example are given by (19) as

$$T = \begin{bmatrix} 1 & 0 \\ 0 & \frac{s-1}{s+2} \end{bmatrix} \begin{bmatrix} V_1 & 0 \\ 0 & V_2 \end{bmatrix}.$$

The optimal controller that minimizes the  $H_2$  norm of the reference-to-error transfer matrix is determined from (21), channel by channel. Clearly,  $V_1 = 1$ . To optimize  $V_2$ , the inner-outer factorization of

$$F_2 = \frac{s-1}{s+2}$$

is seen to be

$$F_{2I} = \frac{s-1}{s+1}, \quad F_{2O} = \frac{s+1}{s+2}$$

and the strictly proper part of

$$F_{2I}^* = \frac{s+1}{s-1}$$

equals

$$F_{2Isp}^* = \frac{2}{s-1}.$$

Thus, from (21),

$$V_2 = \frac{s+2}{s+1}.$$

It follows from (23) that the unique optimal  $R$  is

$$R = \begin{bmatrix} 2 & -\frac{s+2}{s+1} \\ -1 & \frac{s+2}{s+1} \end{bmatrix}$$

and the overall system has the transfer function

$$T = \begin{bmatrix} 1 & 0 \\ 0 & \frac{s-1}{s+1} \end{bmatrix}.$$

The parameter  $W$  does not affect the transfer function  $T$ . It is related to the internal structure of the decoupling controller. For example,  $W = 0$  results in a fairly simple feedback controller. Another choice of  $W$  may provide a robustly stabilizing controller.

## 8. Conclusion

An optimal  $H_2$  decoupling control problem has been studied in the most general setting, for systems in which the measurement output may be different from the output to be decoupled and for dynamic controllers that feature both feedback and feedforward parts. The class of all such controllers that decouple and stabilize the system has been determined in parametric form and the parameter has been used to obtain the  $H_2$ -optimal controller.

The main contribution of the present paper is in a streamlined and transparent exposition and a simple and direct solution of the optimal decoupling control problem, see Kučera (2011). This is primarily because of the following facts. The adopted controller configuration is ideally suited to decoupling since stability and noninteraction can be treated as two independent constraints. The problem is formulated and solved using an algebraic approach, namely the notion of proper and stable fractional representations for system transfer matrices. The parameterization of the decoupling controllers is achieved via the Youla-Kučera parameterization of all stabilizing controllers. Finally, the  $H_2$  norm involved in the optimization is minimized using the completion of the squares, which is a simple algebraic technique.

A large body of literature exists on decoupling and related topics. In technical details, the present paper draws inspiration from the work of Hautus and Heymann (1983) for the formulation of the problem, from Kučera (1983) for the

algebraic treatment of stability, from Desoer and Gündes (1986) for the parameterization of the decoupled system, and from Lee and Bongiorno (1993) for the optimal control.

The matrix fraction approach presented in this paper can be also applied to a class of linear, time-invariant, singular systems that possess a transfer function. This is a subject of current research.

## References

- BASILE, G. AND G. MARRO (1970) A state space approach to non interacting controls. *Ric. Autom.* **1**, 68-77.
- BONGIORNO, J.J. AND D.C. YOULA (2001) Wiener-Hopf design of optimal decoupling one-degree-of-freedom controllers for plants with rectangular transfer matrices. *Int. J. Control* **74**, 1393-1411.
- DENHAM, M.J. (1973) A necessary and sufficient condition for decoupling by output feedback. *IEEE Trans. Automatic Control* **18**, 537.
- DESCUSSE, J. AND M. MALABRE (1982) Solvability of the decoupling problem for linear constant  $(A, B, C, D)$ -quadruples with regular output feedback. *IEEE Trans. Automatic Control* **27**, 456-458.
- DESCUSSE, J. AND J.M. DION (1982) On the structure at infinity of linear square decoupled systems. *IEEE Trans. Automatic Control* **27**, 971-974.
- DESCUSSE, J., J. F. LAFAY, AND V. KUČERA (1984) Decoupling by restricted static state feedback: The general case. *IEEE Trans. Automatic Control* **29**, 79-81.
- DESOER, C.A., R.W. LIU, J. MURRAY, AND R. SAEX (1980) Feedback system design: The fractional representation approach to analysis and synthesis. *IEEE Trans. Automatic Control* **25**, 399-412.
- DESOER, C.A. AND A.N. GÜNDEŞ (1986) Decoupling linear multi-input / multi-output plant by dynamic output feedback: An algebraic theory. *IEEE Trans. Automatic Control* **31**, 744-750.
- FALB, P.L. AND W.A. WOLOVICH (1967) Decoupling in the design and synthesis of multivariable control systems. *IEEE Trans. Automatic Control* **12**, 651-659.
- FILEV, D.P. (1982a) Some new results in state space decoupling of multivariable systems. I. A link between geometric and matrix methods. *Kybernetika* **18**, 215-233.
- FILEV, D.P. (1982b) Some new results in state space decoupling of multivariable systems. II. Extensions to decoupling of systems with  $D \neq 0$  and output feedback decoupling. *Kybernetika* **18**, 330-344.
- GILBERT, E.G. (1969) The decoupling of multivariable systems by state feedback. *SIAM J. Control* **7**, 50-63.
- GÓMEZ, G.I. AND G.C. GOODWIN (2000) An algebraic approach to decoupling in linear multivariable systems. *Int. J. Control* **73**, 582-599.
- HAUTUS, M.L.J. AND M. HEYMANN (1983) Linear feedback decoupling – Transfer function analysis. *IEEE Trans. Automatic Control* **28**, 823-832.

- HAZLERIGG, A.D.G. AND P.K. SINHA (1978) A non-interacting control by output feedback and dynamic compensation. *IEEE Trans. Automatic Control* **23**, 76-79.
- HOWZE, J.W. (1973) Necessary and sufficient conditions for decoupling using output feedback. *IEEE Trans. Automatic Control* **18**, 44-46.
- HOWZE, J.W. AND J.B. PEARSON (1970) Decoupling and arbitrary pole placement in linear systems using output feedback. *IEEE Trans. Automatic Control* **15**, 660-663.
- KAVANAGH, R.J. (1957) Noninteracting controls in linear multivariable systems. *AIEE Trans. Applications and Industry* **76**, 95-100.
- KOUSSIOURIS, T.G. (1979) A frequency domain approach to the block decoupling problem. *Int. J. Control* **29**, 991-1010.
- KUČERA, V. (1975) Stability of discrete linear feedback systems. In: *Preprints 6th IFAC Congress* **1**. IFAC, paper 44.1.
- KUČERA, V. (1979) *Discrete Linear Control: The Polynomial Equation Approach*. Wiley, Chichester.
- KUČERA, V. (1983) Block decoupling by dynamic compensation with internal properness and stability. *Probl. Control Info. Theory* **12**, 379-389.
- KUČERA, V. (2011) Decoupling optimal controllers. In: *Proc. 18th International Conference on Process Control, Štrbské Pleso, Slovakia*. Slovak University of Technology, Bratislava, 400-407.
- KUČERA, V. (2012) Optimal and suboptimal decoupling controllers. In: *Proc. 5th IEEE Internat. Symp. Communications, Control and Signal Processing*, Roma. IEEE, New York, paper 002, 1-4.
- LEE, H.P. AND J.J. BONGIORNO (1993) Wiener-Hopf design of optimal decoupling controllers for plants with non-square transfer matrices. *Int. J. Control* **58**, 1227-1246.
- LIN, C.A. (1997) Necessary and sufficient conditions for existence of decoupling controllers. *IEEE Trans. Automatic Control* **42**, 1157-1161.
- MEJEROV, M.V. (1965) *Multivariable Control Systems* (in Russian). Nauka. Moscow.
- MORGAN, B.S. (1964) The synthesis of linear multivariable systems by state feedback. In: *Proc. Joint Automatic Control Conference*. ASME, New York, 468-472.
- MORSE, A.S. AND W.M. WONHAM (1970) Decoupling and pole placement by dynamic compensation. *SIAM J. Control* **8**, 317-337.
- MORSE, A.S. AND W.M. WONHAM (1971) Status of noninteracting control. *IEEE Trans. Automatic Control* **16**, 568-581.
- PARK, K.H. (2008a)  $H_2$  design of one-degree-of-freedom decoupling controllers for square plants. *Int. J. Control* **81**, 1343-1351.
- PARK, K.H. (2008b) Existence conditions of decoupling controllers in the generalized plant model. In: *Proc. 47th IEEE Conf. Decision and Control*. IEEE, New York, 5158-5163.

- SILVERMAN, L.M. AND H.J. PAYNE (1971) Input-output structure of linear systems with application to the decoupling problem. *SIAM J. Control* **9**, 199-233.
- STREJC, V. (1960) The general theory of autonomy and invariance of linear systems of control. *Acta Technica* **5**, 235-258.
- VOZNESENSKIJ, I.N. (1936) A control system with many outputs (in Russian). *Avtomat. i Telemekh.* **4**, 7-38.
- VIDYASAGAR, M. (1985) *Control System Synthesis: A Factorization Approach*. MIT Press, Boston.
- WOLOVICH, W.A. (1974) *Linear Multivariable Systems*. Springer, New York.
- WONHAM, W.M. (1974) *Linear Multivariable Control*. Springer, New York.
- WONHAM, W.M. AND A.S. MORSE (1970) Decoupling and pole assignment in linear multivariable systems: A geometric approach. *SIAM J. Control* **8**, 1-18.
- YOULA, D.C. AND J.J. BONGIORNO (2000) Wiener-Hopf design of optimal decoupling one-degree-of-freedom controllers. *Int. J. Control* **73**, 1657-1670.
- YOULA, D.C., H. JABR, AND J.J. BONGIORNO (1976) Modern Wiener-Hopf design of optimal controllers – Part II: The multivariable case. *IEEE Trans. Automatic Control* **21**, 319-338.